



# Certificate of Compliance

**Certificate:** 2440884

**Master Contract:** 216815

**Project:** 2440884

**Date Issued:** August 20, 2012

**Issued to:** **BriskHeat Corp**  
**1055 Gibbard Ave**  
**Columbus, OH 43201**  
**USA**  
**Attention: Doug Dietz**

*The products listed below are eligible to bear the CSA Mark shown*



*D. Hawkes*

**Issued by:** D. Hawkes

## **PRODUCTS**

### **CLASS 2872 01 - HEATERS - Cable and Cable Sets**

Heating Cable Sets (usages G, W, S) – Constant Wattage parallel heating cable, type “FE-CAB”, with FEP insulation, FEP inner jacket, shielding, and optional FEP overall jacket, rated 120V ac and 240V ac, maximum continuous exposure temperature of 232°C max, 20A per circuit maximum, for use with supply lead and end connection kits: FE-CAB-KC, FE-CAB-UC, FE-CAB-SK, FE-CAB-EP, FE-CAB-LP.

- for embedded floor warming, soil heating, snow melting, roof de-icing, up to 12W/ft max.

- for pipe & vessel tracing, up to 18W/ft max.

Notes:

1. Installation in accordance with the Canadian Electrical Code Part I.
2. Manufacturer’s minimum recommended installation temperature: -30°C.

## **APPLICABLE REQUIREMENTS**

CAN/CSA-C22.2 No 130-03 - Requirements for Resistance Heating Cables and Heating Device Sets